## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

## FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM





**LISTING No.** 7135-0328:0158 Page 1 of 1

CATEGORY: 7135 -- AUDIBLE DEVICES

LISTEE: Potter Electric Signal Co1609 Park 370 Place, Hazelwood, MO 63042

Contact: Bill Witherspoon (314) 595-6900 Fax (314) 595-6999

Email: BillW@pottersignal.com

**DESIGN:** Model \*HP-25T \*audible signal appliances. \*Intended for installation in a suitable single-gang

electrical box. Refer to listee's data sheet for additional detailed product description and

operational considerations.

RATING: \*16-33 VDC 24 VDC nominal

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical ratings and UL label.

APPROVAL: Listed as \*audible signal appliances for use with separately listed compatible fire alarm

control units. \*Refer to listee's Installation Instruction Manual for details.

NOTE: If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation signal (for total

evacuation) in accordance with NFPA 72, 2002 Edition is required, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Model HP-25T employs a selectable temporal tone. Model HP-26 requires the use of AMESCO

Model TMP1-3B temporal module.

\*Rev 5-17-2007 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: July 01, 2012 Listing Expires June 30, 2013

Authorized By: JASON DEWITT, Deputy State Fire Marshal

Fire Engineering Division